

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE

1

OF PAGE

1

2. AMENDMENT/MODIFICATION NO.

0003

3. EFFECTIVE DATE

07/22/09

4. REQUISITION/PURCHASE REQ. NO.

5. PROJECT NO. (If applicable)

6. ISSUED BY

CODE

OASAM/Office of Procurement Services
U.S. Department of Labor
Rm. N-4308
200 Constitution Ave., NW
Washington, DC 20210

7. ADMINISTERED BY (If other than Item 6)

CODE

8. NAME AND ADDRESS OF CONTRACTOR

(No., street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NO.

DOL099RB20702

X

9B. DATED (SEE ITEM 11)

05-19-2009

10A. MODIFICATION OF CONTRACT/ORDER NO.

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Solicitation No. DOL099RB20702 - New Dormitories at the St. Louis Job Corps Center, is amended as follows:

a. See attachment for details.

b. Bidders must acknowledge receipt of this amendment in Block 19 of Standard Form 1442. Failure to acknowledge receipt of this amendment may render this bid non-responsive.

c. Other than the changes made herein, all other terms and conditions remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

BY _____
(Signature of Contracting Officer)

U.S. Department of Labor
Solicitation No. DOL099RB20702
New Dormitory Buildings
St. Louis Job Corps Center
St. Louis, MO

Amendment No. 3

Solicitation No. DOL099RB20663

Amendment 3

Table of Contents

Section 1 Response to Questions.....3, 4, 5

Section 2 Current Plan Holder's List

SECTION 1 - RESPONSE TO QUESTIONS

1. **Spec Section 07170; Please provide the locations for the waterproofing.**

Response: Waterproofing is required for tunnel enclosure as shown on detail 11/A1-5.

2. **Detail 3/A7-6; Please designate on the plans which closets are Cloth or Linen Closets so that the number and type of shelving to be installed in each can be determined.**

Response: There is one linen closet "L" indicated on detail 1/A7-1 in the Lav. Closets with the designation "CL" in all of the room layouts on that sheet are clothes closets and have a typical notation designating the hardware that corresponds to the detail for "cloth clo." on detail 3/A7-6.

3. **Sheet A1-7 Details 6 through 17. The details show the bottom rail and the fence fabric changing heights (stair stepping) at each post location. Can the bottom rail and fence fabric run at a slope with no gap to exceed 3 1/2"?**

Response: The bottom rail shall be level. No gap shall exceed 3 1/2".

4. **Sheet A1-7 Details 6 through 17. The details show the concrete footings for the posts being 2'-6" below grade through the concrete pad. Are the posts to be installed prior to the concrete pad being poured?**

Response: The posts can be installed prior to the concrete pad being poured.

5. **Sheet A1-7 Details 6 through 17. The details show the concrete footings for the posts being 2'-6" below grade through the concrete pad. Is sonotube going to be installed to provide a void in the concrete slab so that the footings for the posts can be augered after?**

Response: Sleeved or core drilled is acceptable as long as joint is less than 3/8".

6. **Sheet A1-7 Details 6 through 17. The details show the concrete footings for the posts being 2'-6" below grade through the concrete pad. Can the concrete slab be installed with sleeves to accept the posts after it is finish with a grout fill around posts?**

Response: Sleeves on concrete slab is acceptable. But the posts shall be supported by the concrete footing below.

7. **Specification Section 08821 , Item 2.3.A; The detailed drawings of the fence show a top and bottom rail. Which is correct?**

Response: The details call for both top and bottom rail.

8. **Sheet A6-2, Door Schedule shows doors II-D44 & III-D44a having hardware set Group 26. Specs do not show a Group 26. Please clarify.**

Response: There is no Group 26; it should read Group 16.

9. **Sheet A6-2, Note #5 says all exterior frames to be grouted solid but on sheet A6-3, it says all frames shall be grouted solid. Please clarify.**

Response: All exterior door frames shall be grouted solid. No grouting is required for interior door frames.

- 10. Elevation 3/A3-4 shows all 3 second story windows to be type 'F'. Elevation 1/A3-5 shows two window type 'F's and 1 window type 'E'. Which is correct?**

Response: The elevation is correct. Type 'E' operable window is required for the Director's Office.

- 11. Assume that window types 'J' & 'K' are on either side of vestibule door #40 at Honor dorm?**

Response: Types 'J' & 'K' are on either side of vestibule door as shown on elevation sheets A3-3 and A3-5.

- 12. Sheets A2-3 & A2-5 refer to an enlarged plan at entrance vestibule noted 10/A1-10. There is no such detail. Please clarify.**

Response: There are no Sheets A1-10 and A1-11; A1-10 should read A1-6. A1-11 should read A1-7.

- 13. At Dorm #3, sheet A2-12, there are trusses designated T2n, T8d & T8g but we are not given profiles for these trusses. Please clarify.**

Response: There are no Truss Types T2n, T8d and T8g; T2n should read T2g. T8d and T8g should read T8c.

- 14. Detail 1/A4-2 calls for dormer outriggers to be spaced 24" O.C. but sheet S6.1 shows the dormer outriggers at 16" O.C. Please clarify.**

Response: The dormer outriggers shall be at 16" O.C.

- 15. Reference Drawing C-6 and E-10: Drawing C-6 shows the communication conduit at Dorm II entering the building on the northwest corner. Drawing E-10, Note 4 shows the conduit entering the building on the south elevation at Room II-118. Please advise which is correct. NOTE: This condition also occurs at Dorm III (Drawing C-6 and E-12) opposite hand.**

Response: The location of the telephone backboard referred to by note 2 and the location of the communication conduit referred to by note 4 as shown on sheet E-10 shall be moved from STO. #2 to STO. #1. The backboard shall be attached to the wall opposite LC3, P1D & P1E.

- 16. Reference Drawing C-6: Drawing Key Note 23 indicates we are to provide a new communications box. Please advise what size box will be required.**

Response: The communication box shall be 3'X3'X3' deep. The basis for design is box by Quazite with frame no. #PG3636BA36 and cover #PG3636CA00.

- 17. Reference Drawing C-7: Drawing Key Note 21 indicates we are to provide a new precast underground vault structure. Please advise what size vault structure will be required.**

Response: See the vault detail on sheet C-10.

- 18. Reference Drawing C-7: Drawing Key Note 21 references a detail on Drawing C-11. Drawing C-11 was not issued as part of the construction documents. Please advise where the correct detail is located or if this drawing will be issued in an Amendment.**

Response: The note is in error. The vault detail is on sheet C-10.

- 19. On your details you show wood trusses to be sitting on CMU wall directly. Truss manufacturers are concerned that since the trusses are not treated this could be a problem. Please advise. Top of wall shows anchors for trusses, are you calling for drilled anchors or cast in place?**

Response: The Simpson TSS2 will act as a vapor barrier for the truss, so the trusses do not need to be treated. All Simpson truss anchors for the truss need to be embedded in the CMU bond beam.

- 20. Builder's Risk Insurance—we cannot find in the specs if earthquake or flood insurance is required.**

Response: Earthquake and flood insurance are not required. See Section G, G-12 "Required Insurance" referenced in the solicitation.

- 21. Plan holders' List—our company is not listed on the plan holders' list. How can this be fixed?**

Response: It will be included in the plan holders' list for this amendment, attached.

- 22. The air device schedule is very vague as to which model of supply diffuser is required. Please clarify which model is the design intent. There are a number of aluminum diffusers. (TDC, TMS, OMNI, PAS, ETC) Also, concerning air device tagged "S1"...this device is in a hard ceiling and the schedule is calling for a lay-in panel. This would entail that a TRM frame is needed for each device adding substantial cost to the project. Is this correct?**

Response: The ceiling mounted supply diffusers are designed around Krueger model 51400 diffusers. The diffuser "S1" is scheduled as a surface mounted diffuser similar to "S4". The TRM frame will not be required.

DOL Solicitation #DOL099RB20702

Plan available 6-3-2009 at Mak Architects' Office

Site Walk-thru at 6-17-2009 1PM CDT

Bid Open at Mak Architects' Office Jul-22-09 2PM CDT

NAICS 236220

Small Business Standard

100% Small Business Set Aside

Request must be in writing and a \$500 refundable bid-deposit in form of check payable to USDOL

Plan #	Works	Check Rec	Bidder's name/Address/Email/Phone/Fax	PickUp/Date	Send to/Date
1	general	√	Hummel Construction, 127 E. Main Street, Ravenna, OH 44266 P330.296.7316; F330.296.7780	6-3 pick up	6-3 UPS
2	general	√	Morrissey Construction, 705 SouthMoor Place, P.O. Box 189, Godfrey, IL 62035 P618.466.3112; F618.466.9284 ryanmorrissey@morrisseyconstruction.com	6-3 pick up	3-Jun
3	genral	√	Morrissey	6-3 pick up	3-Jun
4	general	√	Raineri Construction 5400 Devonshire Ave, St. Louis, MO 63109 P314.667.5913; F314.667.5638	6-3 pick up	3-Jun
5	general	√	Castle Contracting760 south 2nd St, St. Louis, MO 63102 P314.421.0042; F314.231.9157 jamie@castlestl.com	6-3 pick up	3-Jun
6	general	√	Brinkmann Constructors 16650 Chesterfield Grove Rd St.100,MO63005 P636.537.9700; F636.537.9880 Kevin.Lasater@AskBrinkmann.com	6-3 pick up	3-Jun
7	general	√	Volk Construction 1737 Macklind Ave. MO 63110 P314.776.8655; F314.776.1189 msv@volkcc.com	6-4 pick up	4-Jun
8	general	√	HOF Construction 3137 Jameson St. Louis, MO 63139 P314.645.2200; F314.645.2653	6-4 courier	4-Jun
9	general	√	HOF Construction	6-3 courier	4-Jun
10	general	√	J.E. Novack Construction, 1144 Olivette Executive Pkw, Ste 100 MO63132 P314.567.6100; F314.567.0809 JENOVACK@JENOVACK.COM	6-4pick up	4-Jun
11	general	√	KCI Construction 10315 lake Bluff Dr, STL, MO 63123 p314.894.8888; F314.894.7418 tomhuster@kciconstruction.com	6-4 pick up	4-Jun
12	general	√	Greenlead Construction 3303 Gillham Rd, Kansas City, MO64109 P816.333.3445; F816.333.3449 bill@greenleafconst.com	6-5 pick up	5-Jun
13	general	√	Walton Construction 16024 Manchester R, Ste 111, Ellisville MO 63011 P636.594.2220; F636.594.2240 melissagockel@waltonbuilt.com	6-8 pick up	8-Jun
14	general	√	James Construction 243 East Main St, Ste 203, Carnegie, PA15106 P412.278.3720; F412.278.3721	6-8 FedEx	6-8 FedEx

15	general	√	Propipe Corp, 9832 Reavis Rd, STL, MO 63123 P314.638.7000	6-8 pick up	8-Jun
16	Plan Rm	Waive	AGC of Missouri/ePlan, 1221 Jefferson ST., Lower Level, Jefferson city, MO65109 P573.634.5874; F573.634.5875 gwehmeyer@agcmo.org	6-10 FedEx	6-10 FedEx
17	sub	√	Berkeley Lumber, St. Louis, MO 63134(on behalf of KCI)	6-10 pick up	10-Jun
18	sub	√	Bieg Plumbing, 2015 Lemay Ferry Rd, St. Louis, MO63125	6-10 pick up	10-Jun
19	sub	√	Premiere Hardwoods, 4261 Crescent Ind. Dr. Granite City. IL62040 jschuler@premierehardwoods.com	6-10 pick up	10-Jun
20	sub	√	Con-Tech Building Components, Inc. 366 W. Fourth Street, Eureka, MO 63025 P636.366.9100; F636.366.9030 donmolitor@contechtruss.com	6-10 pick up	10-Jun
21	general	√	R.G.Ross Construction,4079 Bayless Ave, St. Louis, MO 63125 P314.638.9255; kellyg@rgross.com	6-10 pick up courier	10-Jun
22	sub	√	Kay-Bee Electrical Contractor, 250 Reu St., Francois, Florissant, MO 63031 P314.837-3308 jfk@kaybeeelectric.com	6-11 pick up	11-Jun
23	sub	√	Wm.G.Cocos Co. Inc. Complete Plumbing Service, 738 Lemay Ferry Rd, STL,MO63125 P314.631.2688; F314.631.2791	6-11 pick up	11-Jun
24	Plan Rm	waive	Dodge Plan Room, 1702 Broadway, Kansas City, MO64108 P866.223.3876x16; F800.465.7009 roger_davidson@mcgraw-hill.com	6-11 pick up courier	11-Jun
25	sub	√	Schneider Electric Company, 6115 Eveline, STL, MO63139 P644.4700x326; F314.446.7568 rreichert@schneiderelec.com	6-11 pick up	11-Jun
26	sub	√	Sundermeyer LTD, 12896 Pennridge Dr., Bridgeton, MO 63044 P314.344.3288; Jeff@sundermeyerltd.com	6-15pick up	15-Jun
27	sub	√	Trojahn Plumbing Systems, 1601 Sublette Ave., STL, MO63110 P 314.333.3363; F314.333.3370 sidt@trojahnplumbing.com	6-15 pick up	15-Jun
28	sub	√	Crown Electrical Contracting, 3630 s. Broadway, STL MO 63118 P 314.865.3888 jbarr@crownelectrical.com	6-15 pick up	15-Jun
29	sub	√	DeLuca Plumbing, L.L.C. Mechanical Contractors, 8465 Delport Dr. STL MO 63114 P 314.427.5551; F 314.427.1137	6-15 pick up	15-Jun
30	general	√	Knoebel Construction, Inc. 801-805 N. 2nd Street, Ste 204, STL MO 63102 P 314.421.3511; F 314.421.5052 rvenhaus@knoebelcon.com	6-16 pick up	16-Jun
31	Plan Rm	waive	Construction Assistance Program P 314.645.3398; F 314.645.3899 CAP@stlouis.missouri.org	6-16 pick up	16-Jun
32	sub	√	Perfection Steel Erection, 1334 Lonedell Road, Arnold, MO 63010 P 565-5738 Greg.Anderson@perfectionsteelerection.com	6-16 pick up	16-Jun

33	sub	√	Haberbergerinc Mechanical Contractors, 9744 Pauline Place, STL, MO63123 janb@haberbergerinc.com	6-16 pick up	16-Jun
34	sub	√	Hanenkamp electric Company, International Plaza Court, P.O. Box 160 St. Ann MO 63074 p 314.423.2666	6-16 pick up	16-Jun
35	sub	√	Finch Plumbing Co. Inc. 727 spirit of St. Louis Blvd., Chesterfield, MO 63005 P 636.532.4666 finchjim@earthink.net	6-16 pick up	16-Jun
36	sub	√	Imperial Ornamental Metal Co, Inc. 635 So. Old Hwy 141, Box 733, Fenton, MO63026 p 636.343.8825; office@iom-inc.com	6-17 pick up courier	17-Jun
37	General	√	Paric Preconstruction Services, P 636.561.9530; F 636.561.9503 JCSmith@paric.com	Pick up courier	18-Jun
38	"	√	Paric Preconstruction Services,	Pick up courier	18-Jun
39	sub	√	Stark Truss Company, 714 Autumn Glen Lane Wentzville, MO 63385 P 330.478.2100	6-18 pick up	18-Jun
40	sub	√	Powertech Electric, Inc 159 Chesterfield Ind. Blvd., Chesterfield. MO63005 P 636.532.9495; F 636.530.1855	6-19 pick up	19-Jun
41	General	√	Castle Contracting 760 south 2nd St, St. Louis, MO 63102 P314.421.0042; F314.231.9157 jamie@castlestl.com	6-22 pick up courier	22-Jun
42	sub	√	Frueh Services, 9 Progress Dr. Union, MO 63084 P 636.583.3780; F 636.583.2338	6-22	UPS
43	Plan Rm	waive	iSqFt Plan Room, 78Weldon Parkway, Maryland Heights MO 63043 Mike Seidel C314.220.5135; P636.728.5135 bsharma@ISQFT.COM	6-19 pick up	6-19 FedEx
44	DOL		DOL		
45	DOL		DOL		
46	plan Rm	waive	Reed Construction Data, 30 Technology Pkwy S., Suite 500, Norcross, GA 30092	6-22 ordered	UPS
47	sub	√	Consolidated electrical & Mechanicals, 1432 Kingsland, MO 63133 P 314.721.2530 F 314.721.4517	6-23 pick up	23-Jun
48	sub	√	Corrigan Co, Plumbing, 3545 Gratiot, STL MO 63103 P 314.881.6392; F 776.5643	6-23 pick up	23-Jun
49	general	√	Gundaker Commercial Group, p 314.220.5135	6-23 pick up	23-Jun
50		√	KisaQ, 11990 Grant Street, Northglenn, CO 80233 P 303.920.9340; F303.255.3105	6-23 pick up	6-24 FedEX

51	general	√	Hankins Construction	6/24 pick up	24-Jun
52	general	√	Hankins Construction	6/24 pick up	24-Jun
53	general	√	Interface,	6-24 pick up	24-Jun
54	sub	√	Behlman Builders	6-24 pick up	24-Jun
55	sub	√	American electric & Data, 112 Saint Charles Street, M) 63365 P: 636.398.8811	6-25 pick up	25-Jun
56	general	√	ICR Construction Services, 12741 St. Charles Rock Rd. Bridgeton, MO 63044	6-29 pick up	29-Jun
57	sub	√	Gypsum Associates, 5500 Heege Rd., St. Louis, MO 63123 P; 314.351.0445	6-29 pick up	29-Jun
58	sub	√	Kupferer Bros. Ornamental, 8701 Grant, St. Louis, Mo 63123 P;314.843.6030	6-29 pick up	29-Jun
59	sub	√	Von Alst Operating, (drywall) 2146 Smelting Works Rd, Swansea, IL62226 P:318.234.0477	6-29 pick up	29-Jun
60	sub	√	Stone Fabricators,4084 Bingham Ave., STL, MO 63116 P:314.776.7776	6-30 pick up	30-Jun
61	sub	√	Kardell Plumbing, 5624 south Compton, STL, MO 63111 P: 314.352.2202; F:314.352.2638	6-30 pick up	30-Jun
62	sub	√	Marble & Granite Worldwide, 2117 Sams Dr., Des Peres, MO 63131 P: 314.966.4747	7-1 pick up	1-Jul
63	sub	√	St. Louis Electric, Inc. 400N. 4th Street, STL, MO 63102 P: 314.534.3000	7-2 pick up	2-Jul
64	sub	√	R.G.Ross, 4079 Bayless Ave., STL, MO 63125 P: 314.638.9255; F: 314.638.3021	7-2 pcik up	2-Jul
65	sub	√	MCI Mechanical Contractors, Inc. 227 Ferry St, Fenton, MO 63026 P: 314.367.7055;	7-2 pcik up	2-Jul
66	gen	√	Poettker Construction, 380 south Germantown Rd., Breese, IL 62230 P: 618.526.7213, 314.994.0004	7-2 pcik up	2-Jul
67	gen	√	Poettker Construction	7-2 pcik up	2-Jul
68	sub	√	Earley Plumbing Inc, 805 Phaeton Dr., Manchester, MO63021 P: 636.394.7968; F:636.394.7969	7-2 pcik up	2-Jul

69	sub	√	Dickherber Electric, 1708 S. Fifth St., St. Charles, MO 63302 P: 636.946.6432; F: 636.946.1037	7-6 pick up	6-Jul
70	sub	√	American Direct, Operating Account, 11000 Lakeview Ave., Lenexa, KS 66219 P:800.593.5310	7-8 pick up courier	8-Jul
71	sub	√	RJP Electric, 3608 South Big Bend Blvd., STL, MO 63143	7-9 pick up	9-Jul
72	sub	√	E & M Plumbing, 101 Dreyer Ave., Eureka, MO 63025 P: 636.938.1311	7-8 pick up	8-Jul
73	sub	√	Total Lock & Security, 11772 Westline Ind. Dr., STL, MO 63146 P: 314.298.3433; F: 314.298.0944	7-8 pick up	8-Jul
74	sub	√	Fronabarger Plastering Inc., 2326 Gloucester Rd, High Ridge, MO 63049	7-9- pick up	9-Jul
75	sub	√	Scott-Lee, 11010 Gravois Industrial Court, St. Louis, MO 63128 P: 314.756.9444	7-9 pick up	9-Jul
76	sub	√	Missouri Valley Glass Co., 2080 Elm Point Ind. Dr. St. Charles, MO 63301 P:636.946.0900	7-13 pick up	13-Jul
77	sub	√	Demien Construction, P.O .Box 336 P: 636.332.5500	7-13 pick up	13-Jul
78	sub	√	Christian Brothers, P.O. Box 37, Addieville, IL 62214 P: 618.424.5316	7-13 pick up	13-Jul
79	sub	√	West Park Painting, 254 Hanley Ind. Ct. STL, MO 63144 P: 314.962.4884	7-13 pick up	13-Jul
80	sub	√	Accurate Fire Protection, 1428 Gravois Rd., High Ridge, MO 63049	7-13 pick up	13-Jul
81	sub	√	Fletcher Mechanical, 6439 Plymouth Ave., Ste.117, STL, MO 63133 P: 727.1551	7-15 pick up	15-Jul
82	sub	√	Gateway Window & Erectors, P.O. Box 236, Pacific, MO 63069 P: 636.271.6200	7-15 pick up	15-Jul
83	general	√	Nolan Contracting, Inc., 12 Nolan Hill Dr., Fenton, MO 63026 P: 636.343.9421	7-15 pick up	15-Jul
84	sub	√	Stephens Floor Covering Co, 2606 Rock Hill Ind. Ct, STL MO 63144 P: 314.918.9696	7-15 pick up	15-Jul
85	sub	√	G & M Marble & Granite, 2100 North 9th , STL, MO 63102 P: 314.664.2002	7-15 pick up	15-Jul
86	sub	√	Heitkamp 16129 Westwoods Business Park, Ellisville, MO 63021 P: 636.230.5973	7-17 pick up	17-Jul
87	sub	√	Peter Heating & Air Conditioning, 377 Travis Blvd., Troy, MO 63379 P: 636.462.5161	7-21 pick up	21-Jul